

P.O 8034

FORM U-1 MANUFACTURER'S DATA REPORT FOR PRESSURE VESSELS
As Required by the Provisions of the ASME Code Rules, Section VIII, Division 1

1. Manufactured and certified by: Refrigeration Valves And Systems Corporation, 1520 Crosswind Dr., Bryan, TX 77808
 (Name and address of Manufacturer)
2. Manufactured for: SUMMIT REFRIGERATION GROUP, N56 W13262 SILVER SPRING RD., MENOMONEE FALLS, WI 53051
 (Name and address of Purchaser)
3. Location of installation: GOLDEN COUNTRY FOODS, 300 MOORE RD., PLOVER, WI
 (Name and address)
4. Type: VERT. 36" X 9' 10" RECIRCULATOR 43136
 (Horiz. vert. or sphere) (Tank, separator, jkt., vessel, heat exch., etc.) (Mfg.'s serial No.)
 --- 43136 REV.3 20327 2008
 (CRN) (Drawing No.) (Nat'l Bd No.) (Year built)
 5. ASME Code, Section VIII, Div. 1 2004 2006 ---
 Edition and Addenda (date) Code Case No. Special Service per UG-120(d)

Items 6-11 incl. to be completed for single wall vessels, jackets of jacketed vessels, shell of heat exchangers, or chamber of multi-chamber vessels.

6. Shell (a) No. of course(s): 1 (b) Overall length (ft. & in.): 8' 0"

Course(s)			Material		Thickness		Long. Joint (Cat. A)			Circum. Joint (Cat. A, B & C)			Heat Treatment	
No.	Out. Dia. in.	Length (ft. & in.)	Spec./Grade or Type		Nom.	Corr.	Type	Full, Spot, None	Eff.	Type	Full, Spot, None	Eff.	Temp.	Time (hr.)
1	36	8' 0"	SA516-70		.375	0	1	NONE	70	2	NONE	65	1130	0.82

7. Heads: (a) SA516-70 0.82 HR., 1130°F (b) SAME
 (Mat'l. Spec. No., Grade or Type) H.T. - Time & Temp. (Mat'l. Spec. No., Grade or Type) H.T. - Time & Temp.

	Location (Top, Bottom, Ends)	Thickness		Radius		Elliptical Ratio	Conical Apex Angle	Hemispherical Radius	Flat Diameter	Side to Pressure (Convex or Concave)	Category A		
		Min.	Corr.	Crown	Knuckle						Type	Full, Spot, None	Eff.
(a)	TOP	.3125	0	---	---	2:1	---	---	---	CONCAVE	--	---	--
(b)	BOT	.3125	0	---	---	2:1	---	---	---	CONCAVE	--	---	--

If removable, bolts used (describe other fastening)

8. Type of jacket --- Jacket closure ---
 (Describe as ogee & weld, bar, etc.)

- If bar, give dimensions --- If bolted, describe or sketch.
 9. MAWP 250 --- psi at max. temp. +300 --- °F Min. design metal temp. -20 °f at 250 psi.
 (internal) (external) (internal) (external) -50 85

10. Impact test NO UCS-66-b at test temperature of --- °F
 (Indicate yes or no and the component(s) impact tested)

11. Hydro., pneu., or comb. test press 325 Proof test ---

Items 12 and 13 to be completed for tube sections

12. Tubesheet ---
 Stationary (Mat'l Spec. No.) --- Dia. in. (subject to press) --- Nom. thk. in. --- Corr. Allow., in. --- Attachment (welded or bolted) ---
 Floating (Mat'l Spec. No.) --- Dia. in. --- Nom. thk. in. --- Corr. Allow., in. --- Attachment ---
 13. Tubes: ---
 Mat'l Spec. No., Grade or Type --- O.D., in. --- Nom. thk. in. or gauge --- Number --- Type (Straight or U) ---

Items 14-18 to be completed for inner chambers of jacketed vessels or channels of heat exchangers.

14. Shell (a) No. of course(s): --- (b) Overall length (ft. & in.): ---

Course(s)			Material		Thickness		Long. Joint (Cat. A)			Circum. Joint (Cat. A, B & C)			Heat Treatment	
No.	Out., Dia. in.	Length (ft. & in.)	Spec./Grade or Type		Nom.	Corr.	Type	Full, Spot, None	Eff.	Type	Full, Spot, None	Eff.	Temp.	Time (hr.)

15. Heads: (a) --- (b) ---
 (Mat'l. Spec. No., Grade or Type) H.T. - Time & Temp. (Mat'l. Spec. No., Grade or Type) H.T. - Time & Temp.

	Location (Top, Bottom, Ends)	Thickness		Radius		Elliptical Ratio	Conical Apex Angle	Hemispherical Radius	Flat Diameter	Side to Pressure (Convex or Concave)	Category A		
		Min.	Corr.	Crown	Knuckle						Type	Full, Spot, None	Eff.
(a)				---	---	---	---	---			---	---	---
(b)													

If removable, bolts used (describe other fastening)

(Mat'l Spec. No., Grade, Size, No.)

16. MAW P --- --- psi. at max. temp. --- --- °F Min. design. metal temp. --- °F at --- psi.
 (internal) (external) (internal) (external)

17. Impact test --- at test temperature of ---

(Indicate yes or no and the component(s) impact tested)

18. Hydro, pneu, or comb, test press. --- Proof test ---

19. Nozzles, inspection, and safety valve openings:

Purpose (Inlet Outlet, Drain, etc.)	No.	Diameter or Size	Flange Type	Material		Nozzle Thickness		Reinforcement Material	How Attached		Location (Insp. Open.)
				Nozzle	Flange	Nom.	Corr.		Nozzle	Flange	
MISC.	1,1,2	8,6,5	---	SA106B	---	S/40	0	INHERENT	*	---	
MISC.	2,1	2,1-1/2	---	SA106B	---	S/80	0	INHERENT	*	---	
MISC.	2,2	1-1/4,3/4	---	SA106B	---	S/80	0	INHERENT	*	---	
RELIEF	1	1/2	---	SA106B	---	S/80	0	INHERENT	*	---	
MISC.	2	3/4	---	SA105	---	3000	0	INHERENT	*	---	

20. Supports: Skirt NO Lugs 0 Legs 3 Others NONE Attached WELDED TO SHELL AND BOTTOM HEAD
 (Yes or no) (No.) (No.) (Describe) (Where and how)

21. Manufacturer's Partial Data Reports properly identified and signed by Commissioned Inspectors have been furnished for the following items of the report:
 (List the name of part, item number, mfg's. name and identifying number)

N/A

22. Remarks: PRESSURE RELIEF DEVICE SUPPLIED BY OTHERS.

* WELDED IN ACCORDANCE WITH FABRICATION DRAWING.
FOR NON-LETHAL, NON-CORROSIVE SERVICE.
PWHT IS NOT A CODE REQUIREMENT.

CERTIFICATE OF SHOP COMPLIANCE

We certify that the statements made in this report are correct and that all details of design, material, construction, and workmanship of this vessel conform to the ASME Code for Pressure Vessels, Section VIII, Division 1.

U Certificate of Authorization No. 18912 Expires Oct. 10, 2010

Date 1-26-08 Name Refrigeration Valves and Systems Corporation Signed [Signature]
 (Manufacturer) (Representative)

CERTIFICATE OF SHOP INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and/or the State or Province of Texas and employed by Onebeacon America Insurance Company of Boston, MA have inspected the pressure vessel described in this Manufacturer's Data Report on 1-28, 20 08, and state that, to the best of my knowledge and belief, the Manufacturer has constructed this pressure vessel in accordance with ASME Code, Section VIII, Division 1. By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the pressure vessel described in this Manufacturer's Data Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date 1-28-08 Signed [Signature] Commissions NB#12355A, TX1681
 (Authorized Inspector) (Nat'l Board Incl. Endorsement, State, Province and No.)

CERTIFICATE OF FIELD ASSEMBLY COMPLIANCE

We certify that the statements on this report are correct and that the field assembly construction of all parts of this vessel conforms with the requirements of ASME Code, Section VIII, Division 1.

U Certificate Authorization No. _____ Expires _____, 20 _____
 Date _____ Name _____ Signed _____
 (Assembler) (Representative)

CERTIFICATE OF FIELD ASSEMBLY INSPECTION

I the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and/or the State or Province of _____ and employed by _____ of _____ have compared the statements in this Manufacturer's Data Report with the described pressure vessel and state that the parts referred to as data items _____, not included in the certificate of shop inspection, have been inspected by me and to the best of my knowledge and belief, the Manufacturer has constructed and assembled this pressure vessel in accordance with ASME Code, Section VIII, Division 1. The described vessel was inspected and subjected to a hydrostatic test of _____ psi. By signing this certificate neither the Inspector nor his employer makes any warranty, express or implied, concerning the pressure vessel described in this Manufacturer's Data Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date _____ Signed _____ Commissions _____
 (Authorized Inspector) (Nat'l Board Incl. Endorsement, State, Province and No.)